

Record of inspection and cleaning

Harbourview Grill — 1710 Comox Avenue, Comox, BC V9M 3M1. Main line hood, solid-fuel appliance. Serviced 31 January 2026.

● Cleaned to code

⚠ 2 areas not accessible

○ Next service 28 Feb 2026

HOODS ON SYSTEM **3**
COOKING VOLUME **Solid fuel**
REQUIRED INTERVAL **Monthly**
WORK SEALED **31 Jan, 23:58 PST**

RECORD **CR-2026-0142**
ISSUED **31 Jan 2026**
ISSUED BY **Northwest Hood Services Ltd.**
ASTTBC RFPT-CO 1182
HASH sha256 4f8a2b91 c07d3e5a 18b6f240
9ad51c73 e62408bf 7351da09
2cf9b845 6e13a07d
TIMESTAMP Independently timestamped by
DigiCert TSA

Measured condition

Grease deposit depth measured at the heaviest accessible point in each duct, before and after cleaning.


HOOD	BEFORE	AFTER	FILTERS	FAN	RESULT
Charbroiler — west	2.4 mm	0.1 mm	Cleaned	Good	● Pass
Wok range — centre	3.1 mm	0.2 mm	Replaced	Good	● Pass
Fryer bank — east	1.8 mm	0.1 mm	Cleaned	Belt worn	⚠ Deficiency

What could not be reached

Each area is recorded with a reason and a photograph, and remains uncleaned until the access noted is provided.

Vertical riser
LEVEL 2 TO ROOF

No access panel fitted between the second-floor ceiling and the rooftop fan. Approximately 4.2 m of duct is unreachable without cutting an inspection opening.



captured 23:12 PST



Horizontal run
ABOVE WALK-IN

Access panel sealed by a subsequent building alteration. The panel frame is visible but has been drywalled over and painted.



captured 23:26 PST

Rules this record was issued under

Resolved for this site's jurisdiction at the moment work began, and frozen.

BC Fire Code 2024 · Div. B 2.6.1.9 Cleaning of commercial cooking exhaust systems

NFC 2020 · Div. B 2.6.1.10 Records of inspection and cleaning

ASTTBC · RFPT-C0 Registered fire protection technician — commercial cooking equipment

Who signed for this work

TECHNICIAN

Sam Reyes
Northwest Hood Services Ltd.
ASTTBC RFPT-C0 1182

I performed this work and the information recorded above is a true account of the condition of the system and of the areas cleaned.

SITE REPRESENTATIVE

Dana Whitfield
Harbourview Grill — night manager

I confirm the work described above was carried out at this site.